

SUBMITTAL RECORD _____
 JOB _____
 LOCATION _____
 SUBMITTED TO _____
 SUBMITTAL PREPARED BY _____
 APPROVED BY _____
 DATE _____



Specification Form DDIAD-0806 Insulated Access Doors

DESCRIPTION

Periodic inspection and testing of fire and smoke dampers and detectors in ductwork is a standard safety procedure. easy access to these devices as well as providing a means of removing dust accumulation can be provided by the installation of hinged access doors. These doors incorporate an integral frame which readily fastens to the duct work as well as a camlock latching system for easy entry.

RELATED NFPA 90A & 90B STANDARDS

2-1.4 Duct Access and Inspection Provisions.

2-1.4.1 A service opening or telescoping or removable duct section shall be provided in ducts adjacent to each fire door, fire damper, smoke damper and smoke detector. The opening shall be large enough to permit maintenance and resetting of the device.

2-1.4.1 Service openings, telescoping or removable duct sections shall be identified with letters no less than 1/2 in. (1.27 cm) in height to indicate the location of the fire protection device(s) within.

2-1.4.3 Horizontal ducts and plenums shall be provided with service openings (see 2-1.4.1) to facilitate cleaning the duct of accumulations of dust and combustible materials. Service openings shall be placed at approximately 20 ft. (6.1-m) intervals along the duct and at the base of each vertical riser.

Exception No. 1: Removable air outlet or air inlet devices of adequate size may be accepted in lieu of service openings.

Exception No. 2: Service openings may be omitted in supply ducts when the supply air has previously passed through air filters or water spray.

Exception No. 3: Service openings are not required when all the following conditions prevail:

(a) The occupancy does not produce combustible material such as dust, lint, greasy vapors, etc. Such occupancies include banks, office buildings, churches, hotels, and health care facilities (but not kitchens, service rooms, and manufacturing portions of such facilities).

(b) The air inlets are at least 7 ft. (2.13m) above the floor or are protected by corrosion-resistant metal screens of at least 14 mes, installed at the inlets so that they will not draw papers, refuse, cigarettes or other combustible solids into the return air duct.

(c) The minimum design velocity in the return duct from the particular occupancy is 1,000 ft/min. (508m/sec.).

SUGGESTED SPECIFICATIONS

Service openings shall be provided in ducts adjacent to each fire door, fire damper, smoke damper and smoke detector. Horizontal ducts and plenums shall be provided with service openings to facilitate cleaning the duct of accumulations of dust and combustible materials. Service openings shall be placed at approximately 20 foot intervals along the duct and at the base of each vertical riser. Service openings shall be sized _____ x _____ and shall incorporate access doors coded _____ as manufactured by Duro Dyne Corporation.



CONSTRUCTION

Door Frame: 24 ga. galvanized steel. Conforms to ASTM-A-591.

Door Face: 24 ga. galvanized steel. Conforms to ASTM-A-591.

Insulation: 1: 1 1/2 lb. Neoprene coated fiberglass (K Factor .26+.03@ 75 F) Conforms to NFPA 90.

Seals: Door to Frame/Frame to Door-Urethane gasket. Conforms to ASTM-D 1692-74. Temperature range-30 F to 260 F .22-.28 K Factor.

Latches: Single Camlock action on all hinged doors 12" square and under. Dual latches on larger hinged sizes. Latches constructed of zinc plated cold rolled steel. Steel conforms to ASTM-A-366. Plating conforms to ASTM-A-164-55.

ITEM#	CODE	DOOR SIZE	CUT HOLE IN DUCT
■ 8230	IAD	6"x6"	4 7/8"x4 7/8"
■ 8168	IAD	8"x8"	6 7/8"x6 7/8"
■ 8169	IAD	10"x10"	8 7/8"x8 7/8"
■ 8170	IAD	12"x12"	10 7/8"x10 7/8"
■ 8171	IAD	14"x10"	12 7/8"x8 7/8"
■ 8167	IAD	14"x14"	12 7/8"x12 7/8"
■ 8172	IAD	16"x16"	14 7/8"x14 7/8"
■ 8173	IAD	18"x18"	16 7/8"x18 7/8"
■ 8174	IAD	20"x20"	18 7/8"x18 7/8"
■ 8175	IAD	24"x24"	22 7/8"x22 7/8"

DUCT INSULATION-INSIDE



WITHOUT DUCT INSULATION



*Plexiglass Window Available Upon Request

Duro Dyne East Division, Bay Shore, NY
 631-249-9000 Fax: 631-249-8346
Duro Dyne Midwest Division, Fairfield, OH
 513-870-6000 Fax: 513-870-6005
Duro Dyne West Division, Santa Fe Springs, CA
 562-926-1774 Fax: 562-926-5778
Duro Dyne Canada, Lachine, Quebec, Canada
 514-422-9760 Fax: 514-636-0328
 www.durodyne.com E-mail: durodyne@durodyne.com

©2006 DURO DYNE CORPORATION
 Printed in the USA 08/06
 BO008402

